

CERTIFICATE OF COMPLIANCE

Certificate Number 20161006- R4339
Report Reference R4339-19910311
Issue Date 2016-October-06

Issued to: GCP Applied Technologies Inc
FIRE OPERATING UNIT
62 WHITTEMORE AVE
CAMBRIDGE MA 02140

**This is to certify that
representative samples of**


SPRAY-APPLIED FIRE-RESISTIVE MATERIALS
CEMENTITIOUS CEMENT AND PLASTER MIXTURES
FIRE-RESISTANCE RATINGS - ANSI/UL 263
SPRAY-APPLIED FIRE RESISTIVE MATERIAL
CEMENTITIOUS MIXTURES
FIRE AND SMOKE PROTECTION
SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: SEE ADDENDUM PAGE FOR Standard(s)
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20161006- R4339
Report Reference R4339-19910311
Issue Date 2016-October-06


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

A mixture of ingredients which when mixed with water form a cementitious mixture.

Type Designations - Z-146, Z-146 NPP, Z-146PC, Z-146T

STANDARDS FOR SAFETY:

UL 263, Fire Tests of Building Construction and Materials
UL 723, Test for Surface Burning Characteristics of Building Materials
UL 1709, Rapid Rise Fire Tests of Protection Materials for Structural Steel
ULC-S101, Standard Methods of Fire Endurance Tests of Building Construction and Materials
ULC-S102M, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

